



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DG-4502CN0373**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	Georg Fischer Fittings GmbH Mariazeller Straße 75, A-3160 Traisen
<b>Distributor</b> <i>Vertreiber</i>	Georg Fischer Fittings GmbH Mariazeller Straße 75, A-3160 Traisen
<b>Product Category</b> <i>Produktart</i>	pipe equipment and fittings: separable unthreaded pipe connection for metal pipes (4502)
<b>Product Description</b> <i>Produktbezeichnung</i>	soluble connection made of malleable cast iron for steel pipes for gas
<b>Model</b> <i>Modell</i>	PRIMOFIT
<b>Test Reports</b> <i>Prüfberichte</i>	laboratory control test: 120000517-15-1 from 22.02.2016 (MPM)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DIN 3387-1 (01.11.2008)

**Date of Expiry / File No.** 31.08.2022 / 17-0321-GNV  
**Ablaufdatum / Aktenzeichen**

03.07.2017 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com

info@dvgw-cert.com

<b>Gas Category</b> <i>Gasart</i>	<b>Remarks</b> <i>Bemerkungen</i>
fuel gases according to G260	

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
PRIMOFIT	nominal diameter: DN 10	
PRIMOFIT	nominal diameter: DN 15	
PRIMOFIT	nominal diameter: DN 20	
PRIMOFIT	nominal diameter: DN 25	
PRIMOFIT	nominal diameter: DN 32	
PRIMOFIT	nominal diameter: DN 40	
PRIMOFIT	nominal diameter: DN 50	
PRIMOFIT	nominal diameter: DN 65	
PRIMOFIT	nominal diameter: DN 80	
PRIMOFIT	nominal diameter: DN 100	

**certified Components**  
*zertifizierte Bauteile / Werkstoffe*

<b>Registr. No.</b> <i>Registrier-Nr.</i>	<b>Component</b> <i>Bauteil (Produktart)</i>	<b>Model/Type</b> <i>Modell/Typ</i>	<b>Manufacturer</b> <i>Hersteller</i>
NG-5113BU0379	Elastomer sealant for gas supply mains and pipelines	TEC N41-70/TEC N41-70	Tecnogomma International S.p.A.
DG-5113CP0070	Elastomer sealant for gas supply mains and pipelines	IRM 0770-26/IRM 0770-26	Industrial Rubber Ltd.

**Hints of Utilization / Remarks**  
*Verwendungshinweise / Bemerkungen*

max. operating pressure: 10 bar (MOP 10)

ambient temperature range: -20...+60 °C

connection: on both sides smooth pipe connection or at the input side smooth pipe connection; at the outlet side internal thread Rp 3/8...Rp 4 or external thread R 3/8...R 4, each according to DIN EN 10226-1

diameters for reduced screw joint only DN 20/DN 15...DN 50/40 respectively angle, tee and cap only DN 10...DN 50