



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511BL0157

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Georg Fischer Fittings GmbH Mariazeller Straße 75, A-3160 Traisen
Distributor <i>Vertreiber</i>	Georg Fischer Fittings GmbH Mariazeller Straße 75, A-3160 Traisen
Product Category <i>Produktart</i>	installation systems and system joints: pipe joint for pipes in drinking water installation systems (8511)
Product Description <i>Produktbezeichnung</i>	clamp fitting type M-MM made of zinc plated malleable cast iron for zinc plated steel pipes, for cold water
Model <i>Modell</i>	PRIMOFIT
Test Reports <i>Prüfberichte</i>	laboratory control test: 120000517-14 from 21.01.2015 (MPM) supplement test: 411.334-2k from 10.06.2014 (MPM) mechanical test: 120004242 from 27.11.2013 (MPM) KTW testing: KA 282/11 from 29.09.2011 (TZW) hygienic testing: MO 094/13 from 05.07.2013 (TZW) KTW testing: KA 286/11 from 17.10.2011 (TZW) hygienic testing: MO 095/13 from 05.07.2013 (TZW)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 534 (01.05.2004) BGA KTW (12.12.1985) DVGW W 270 (01.11.2007)

Date of Expiry / File No. 11.04.2020 / 14-0606-WNV
Ablaufdatum / Aktenzeichen

23.02.2015 GI A-1/2

Date, Issued by Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
PRIMOFIT	nominal diameter: 3/8"	
PRIMOFIT	nominal diameter: 1/2 "	
PRIMOFIT	nominal diameter: 3/4 "	
PRIMOFIT	nominal diameter: 1 "	
PRIMOFIT	nominal diameter: 1 1/4 "	
PRIMOFIT	nominal diameter: 1 1/2 "	
PRIMOFIT	nominal diameter: 2 "	
PRIMOFIT	nominal diameter: 2 1/2 "	
PRIMOFIT	nominal diameter: 3 "	
PRIMOFIT	nominal diameter: 4"	

certified Components

zertifizierte Bauteile / Werkstoffe

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NW-5253BT0306	sealing material for drinking water installations	TIMO 3-70/TIMO 3-70	Tecnogomma International S.p.A.
NW-5213CN0235	Elastomer sealant for gas and water supply mains and pipelines	TEC N41-70/TEC N41-70	Tecnogomma International S.p.A.

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Only to use for cold water.

The testing was made with DVGW-certified zinc steel pipes.

